

Daily Preventative Measures Log

To Be Completed by Constructor

Date:	Time:	Initials	Time:	Initials	Time:	Initials	Time:	Initials	Time:	Initials
Walk off mat checked										
Hoarding checked										
Pressure differential reading ($\geq -7.5\text{pa}$)										
Construction clean (daily and as needed)										
Date:	Time:	Initials	Time:	Initials	Time:	Initials	Time:	Initials	Time:	Initials
Walk off mat checked										
Hoarding checked										
Pressure differential reading ($\geq -7.5\text{pa}$)										
Construction clean (daily and as needed)										
Date:	Time:	Initials	Time:	Initials	Time:	Initials	Time:	Initials	Time:	Initials
Walk off mat checked										
Hoarding checked										
Pressure differential reading ($\geq -7.5\text{pa}$)										
Construction clean (daily and as needed)										
Date:	Time:	Initials	Time:	Initials	Time:	Initials	Time:	Initials	Time:	Initials
Walk off mat checked										
Hoarding checked										
Pressure differential reading ($\geq -7.5\text{pa}$)										
Construction clean (daily and as needed)										

CSA-Z317.13:22 Section 7.3.3.3.3

If the pressure differential is less than 7.5 Pa of negative pressure within the construction zone for more than 4 h, or if it drops to less than 2.5 Pa for more than 90 seconds, the constructor shall take **immediate** corrective measures to restore and maintain the required pressure differential.

Effective Date	February 2025		
Partners Reviewed	FMP, P3 Operations and Capital Planning		
Last Reviewed			
Approved By	IPAC		
Owner	Infection Prevention and Control		
Revision History	Date	Section	Revision