

**Schedule A**  
**Water Quality Standards for Potable Water**

<b>Parameter:</b>	<b>Standard:</b>
Fecal coliform bacteria	No detectable fecal coliform bacteria per 100 ml
<i>Escherichia coli</i>	No detectable <i>Escherichia coli</i> per 100 ml
Total coliform bacteria	
(a) 1 sample in a 30 day period	No detectable total coliform bacteria per 100 ml
(b) more than 1 sample in a 30 day period	At least 90% of samples have no detectable total coliform bacteria per 100 ml and no sample has more than 10 total coliform bacteria per 100 ml

**Schedule B**  
**Frequency of Monitoring Samples for Prescribed Water Supply Systems**

<b>Population Served by the Prescribed Water Supply System:</b>	<b>Number of Samples Per Month:</b>
less than 5 000	4
5 000 to 90 000	1 per 1 000 of population
more than 90 000	90 plus 1 per 10 000 of population in excess of 90 000