


IH Recommended Hand Hygiene Sinks (Type B)

Type Model	Photo	Dimensions	Application
AHWSS1720WIS-00 Nightingale (integrated faucet A/C wired)		Overall (FB x LR x H) 16 15/16" [430mm] x 20 3/16" [512mm] x 21 1/4" [540mm]	Inpatient Areas Corridors Clinical Areas
AHWSS1720WIS-AL Nightingale Wallmount White Hand Hygiene Sink with Integrated Laminar Spout & Antiligature shroud		Overall (FB x LR x H) 16 15/16" [430mm] x 20 7/16" [519mm] x 22 3/8" [568mm]	Mental Health and Addictions where anti-ligature furnishings are recommended
MIX-LF Mixing Valve (FRANKE)			
IWC2203 In-wall Carrier			
Franke: HWSS1518P (stainless steel) with Delta 1500T4670 faucet and RP32508- 20VA Transformer for hardwire connection		18 x 15" Overall. 14 x 14 x 10" Bowl. (FB x LR x D). 457 x 381 mm Overall. 356 x 356 x 254 mm Bowl. (FB x LR x D).	Housekeeping Closets Soiled Utility Rooms Non Clinical Areas

IH Recommended Hand Hygiene Sinks (Type B)

Type Model	Photo	Dimensions	Application
Franke HWSS2321W-00 Hand Hygiene Sink with laminar flow faucet		<p>20 7/16 x 23 15/16" Overall. 17 5/8 x 21 7/16 x 9" Bowl. (FB x LR x D).</p> <p>519 x 607 mm Overall. 448 x 544 x 228 mm Bowl. (FB x LR x D).</p>	ICU's

Summary of Requirements

- Drains shall be corrosion-resistant
- Traps shall be metal, and gaskets shall be plastic or neoprene only.
- Traps shall be 40 mm diameter
- Backsplashes shall extend a minimum 600 mm (2 feet) above sink level and a minimum of 250 mm (10 inches) below sink level
- Backsplashes must be seam-free
- All edges must be sealed with a waterproof barrier
- Backsplashes must include the area under the paper towel dispenser and soap dispenser
- Paper towel dispenser design shall be hands-free
- Paper towel dispensers should be mounted such that access to them is unobstructed and splashing or dripping onto adjacent wall and floor surfaces is minimized
- Paper waste receptacles shall be a corrosion free material and wide mouth design.
- Only liquid soap dispensers (and antimicrobial liquid soap dispensers; if required) shall be installed above the HHS
- Moisturizer lotion and alcohol hand rub dispensers **SHALL NOT** be installed above or immediately adjacent to a HHS
- PPE, e.g. disposable gloves **SHALL NOT** be installed above a HHS
- A current laminated hand washing guide should be posted at each HHS in order to promote correct hand washing technique

Please note: The above are examples of sinks that have been approved for use in IH facilities. Other products may be used after written approval as an approved equivalent through the demonstration of performance.

References

CSA Z317.1-21 Special Requirements for Plumbing Installations in Health Care Facilities

Z8000-18, Canadian health care facilities, July 2018 CSA Group

British Columbia Ministry of Health (Dec 2019) Best Practices for Hand Hygiene: In All Healthcare Settings and Programs

Paul Chisholm, Fraser Health